




- | | |
|---|--|
| 1 SHREDDED BARK / MULCH PER SPECIFICATIONS.
3" THICK COVERAGE MINIMUM | 7 1/2" PVC 90° ELL - FIPT x FIPT |
| 2 FINISH GRADE OF SOIL SURFACE | 8 1/2" MARLEX STREET ELL |
| 3 DRIPPERLINE COMBINATION TEE (INS x INS x 3/4" FPT)
OR END CONNECTION AS APPLICABLE (1/2" PVC
90° ELL S x T WITH 1/2" MPT ADAPTER) | 9 1/2" x 6" SCH 80 NIPPLE |
| 4 DRIPPERLINE TUBING PER PLANS | 10 3/4" MIN PVC LATERAL LINE PER PLANS |
| 5 3/4" MIPT x 1/2" FIPT PVC REDUCER BUSHING | 11 PVC TEE (S x S x T) - SIZE PER PLANS |
| 6 1/2" x 4" SCH 80 NIPPLE | 12 1/2" PVC STREET ELL |
| | 13 6" SOIL STABLE - PLACE APPROX EVERY 3' OF
TUBING, PLUS 2 ON EACH TEE, ELL OR CROSS |

NOTES: 1. ALL DRIPPERLINE FITTINGS SHALL BE OF THE SAME MANUFACTURE AS THE SPECIFIED DRIPPERLINE.
2. USE TEFLON TAPE ON ALL PVC TO PVC CONNECTIONS.

NOT TO SCALE



RECOMMENDED:
 1.16.14
 DIVISION MANAGER DATE
 APPROVED:
 1/29/14
 PUBLIC WORKS DIRECTOR/ DATE
 CITY ENGINEER

CITY OF MORENO VALLEY
 FINANCIAL & MANAGEMENT SERVICES DEPARTMENT - SPECIAL DISTRICTS DIVISION

**PVC PIPE WITH SWING-JOINT
 CONNECTION TO DRIPPERLINE**

STANDARD PLAN
MVLI-574E-0

SHEET 5 OF 12